



**Westchester
Environmental, LLC**

**LEAD IN DRINKING WATER REPORT
ROCKAWAY BOROUGH SCHOOL DISTRICT
FLUSH SAMPLING**

PERFORMED FOR:

ROCKAWAY BOROUGH SCHOOL DISTRICT
103 EAST MAIN STREET
ROCKAWAY, NJ 07886

PERFORMED BY:

WESTCHESTER ENVIRONMENTAL LLC
307 N WALNUT STREET
WEST CHESTER, PA 19380

JUNE 2017



June 22, 2017

Chris Kelly
Rockaway Borough School District
103 East Main Street
Rockaway, NJ 07866

Re: LEAD IN DRINKING WATER REPORT- FLUSH SAMPLING

Mr. Kelly,

Please find enclosed the report for the Lead in Drinking Water Flush sampling conducted for The Rockaway Borough School District.

If you have any questions, please contact me at 610-431-7545 or email me at nabraham@westchesterenvironmental.com.

Sincerely,

Westchester Environmental, LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', is written over a horizontal line.

Noel Abraham
Environmental Specialist



TABLE OF CONTENTS

ROCKAWAY BOROUGH SCHOOL DISTRICT

1.0	INTRODUCTION.....	1
2.0	SUMMARY OF FINDINGS.....	2
3.0	SAMPLING AND ANALYSES.....	4
4.0	DISCUSSION & RECOMMENDATIONS.....	5
5.0	DISCLAIMER.....	6

Appendix I – Water Sampling Chain-of-Custody & Laboratory Reports



1.0 INTRODUCTION

Westchester Environmental, LLC. was contracted by Mr. Chris Kelly to conduct Drinking Water Sampling for Lead at the Rockaway Borough School District.

The water sampling was performed on June 9, 2017 by Noel Abraham and Paul McCaa of Westchester Environmental, LLC.

The purpose of the assessment was to collect flush water samples at locations in the facility where the initial first draw samples were reported to contain lead above the NJDEP action level of 15.5 parts per billion (ppb).

All samples were analyzed by Suburban Testing Labs located at 1037 MacArthur Rd, Reading, PA 19605, a New Jersey certified Lead in Drinking Water testing facility.

-END OF SECTION-

2.0 SUMMARY OF FINDINGS

Tables 1 and 2 compare the results of the follow up flush samples to their corresponding initial first draw samples and also compares the FLUSH samples against the lead action limit. Those FLUSH samples that exceeded the lead action limit are yellow highlighted in these tables.

Table 1: Lincoln Elementary School

Sample Number	Location	First Draw Result	Flush Result	Action Level	Flush Result Over Limit	
		ppb	ppb	ppb	Yes/No	
1	RLES-LFL-S-B-7	B-7	35.4	38.8	15.5	Yes
2	RLES-LFL-S-B-4 -1	B-4-1	15.8	1.95	15.5	No
3	RLES-MFL-S-CR110 -1	CR110-1	36.6	19.8	15.5	Yes
4	RLES-MFL-DW-CR110	CR110	19.3	87.2	15.5	Yes
5	RLES-MFL-S-Principal's Office	Principal's Office	46.1	8.9	15.5	No
6	RLES-MFL-S-Boy's Rm -1	Boy's Rm-1	19.1	9.53	15.5	No
7	RLES-2FL-S-Girl's Rm -4	Girl's Rm-4	19.5	4.72	15.5	No
8	RLES-2FL-S-Girl's Rm -5	Girl's Rm-5	17.9	8.46	15.5	No
9	RLES-2FL-S-Boy's Rm -5	Boy's Rm-5	91.6	89.9	15.5	Yes

Table 2: Thomas Jefferson Middle School

Sample Number	Location	First Draw Result	Flush Result	Action Level	Flush Result Over Limit	
		ppb	ppb	ppb	Yes/No	
1	RJMS-1FL-S-Principals Office 1	Principals Office	27.6	3.12	15.5	No
2	RJMS-1FL-S-Home EC Lab 1	Home Ec Lab	20.7	9.41	15.5	No
3	RJMS-1FL-S-Home EC Lab 3	Home Ec Lab	65.2	28.6	15.5	Yes
4	RJMS-1FL-S-Prep Rm-2	Prep Rm 2	26.6	3.31	15.5	No
5	RJMS-1FL-S-Science Rm 2	Science Rm	16	1.88	15.5	No
6	RJMS-1FL-S-Science Rm 5	Science Rm	18.2	2.41	15.5	No
7	RJMS-1FL-S-Science Rm 7	Science Rm	16.1	1.66	15.5	No
8	RJMS-1FL-S- Girls Locker Rm	Girls Locker Rm	16.7	3.18	15.5	No
9	RJMS-1FL-S-Boys Locker Rm	Boys Locker Rm	15.5	4.78	15.5	No
10	RJMS-1FL-S-Art Rm 1	Art Rm	24.5	2.82	15.5	No
11	RJMS-1FL-DW-Hall o/s Music Rm	Hall o/s Music	17.5	31.9	15.5	Yes
12	RJMS-1FL-S-Kitchen 1	Kitchen	25.8	15.1	15.5	No



13	RJMS-1FL-S-Kitchen 2	Kitchen	34.3	11.9	15.5	No
14	RJMS-2FL-S-CR 101	CR 101	16.6	24.8	15.5	Yes
15	RJMS-1FL-DW-CR 101	CR 101	38.1	7.36	15.5	No
16	RJMS-1 FL-S-CR 102	CR 102	23.9	20.3	15.5	Yes
17	RJMS-1FL-S-Library	Library	32	29.5	15.5	Yes
18	RJMS-1FL-DW-Library	Library	37	16.8	15.5	Yes
19	RJMS-1FL-S-Girls Rm 1	Girls Rm 1	26.6	13.7	15.5	No
20	RJMS-1FL-S-CR 105	CR 105	63	22.7	15.5	Yes
21	RJMS-1FL-DW-CR 105	CR 105	143	85.5	15.5	Yes
22	RJMS-1FL-S-CR 117	CR 117	86.6	9.29	15.5	No
23	RJMS-1FL-S-CR-106	CR 106	396	92.6	15.5	Yes
24	RJMS-1FL-DW-CR-106	CR 106	158	50.3	15.5	Yes
25	RJMS-1FL-S-CR 116	CR 116	25.5	22.4	15.5	Yes
26	RJMS-1FL-S-CR 107	CR 107	81.1	49.8	15.5	Yes
27	RJMS-1FL-DW-CR 107	CR 107	47.4	113	15.5	Yes
28	RJMS-1FL-S-CR 108	CR 108	96.5	152	15.5	Yes
29	RJMS-1FL-DW-CR 108	CR 108	89.5	49.2	15.5	Yes
30	RJMS-1FL-S-CR 115	CR 115	36.8	128	15.5	Yes
31	RJMS-1FL-S-CR 114	CR 114	51.3	11.5	15.5	No
32	RJMS-1FL-S-CR 109	CR 109	107	63.4	15.5	Yes
33	RJMS-1-FL-S-CR 113	CR 113	175	53.6	15.5	Yes
34	RJMS-1FL-S-CR 110	CR 110	86.9	20.6	15.5	Yes
35	RJMS-1FL-DW-CR 110	CR 110	57.9	78.6	15.5	Yes
36	RJMS-1FL-DW-CR 112	CR 112	171	225	15.5	Yes
37	RJMS-1FL-S-CR 112	CR 112	97.5	95.3	15.5	Yes
38	RJMS-1FL-S-CR 111	CR 111	42.6	40.5	15.5	Yes

-END OF SECTION-



3.0 SAMPLING AND ANALYSES

The following guidance documents were followed for all sampling:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Forty seven (47) flush samples were collected and analyzed from the locations where the initial first draw sample was reported to contain lead above the lead action level of 15.5 parts per billion (ppb).

All samples were labeled with a unique identification number and transported to the Suburban Laboratory for analysis for lead in drinking water using EPA Method 200.8.

-END OF SECTION-

4.0 DISCUSSION & RECOMMENDATIONS

According to the US EPA, lead enters drinking water primarily through plumbing materials.

For further information on guidance protocols and Action Levels that were followed please refer to:

1. N.J.A.C. 6A:26
2. Guidance Document from NJDEP Division of Water Supply and Geoscience – “Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water”.
3. The EPA’s Revised Technical Guidance - “3Ts for Reduced Lead in Drinking Water in Schools”

Based on the laboratory analysis of the flush samples, the following are recommended:

1. Continue to keep those locations where any lead levels (either first draw or flush) exceeded the NJDEP 15.5 ppb Action Level off line until corrective actions can be completed. Locations where first draw samples were above the action level and flush samples are below the lead limit are an indication that the fixtures themselves are contributing to the lead concentrations reported. Locations where flushed samples were above the action level are an indication that conditions further back (upstream) in the plumbing system are also contributing to the lead contamination.
2. Refer to EPA’s “**3Ts for Reduced Lead in Drinking Water in Schools**” for other short term and long term suggested remediation measures. These measures may include but are not limited to: cleaning of aerators or screens, decommission of an outlet (taking off line), replacing a fixture or parts of a fixture, installing a lead filter, replacing specific plumbing components. If a location is remediated with intent to be put back in service it must first be re-tested for lead to assure that the remediation performed successfully produces a result under the lead action limit. Further Operations and Maintenance Plans if not already in place should be developed to periodically evaluate those sample points remediated if necessary.
3. Proper notification of these results is required per the NJ regulations.

-END OF SECTION-



5.0 DISCLAIMER

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment only.

Westchester Environmental LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for, and is confidential to, the above noted client. Westchester Environmental LLC assumes no liability with regards to the use of this information or decisions, which are made regarding the subject property. The user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham'.

Noel Abraham
Environmental Specialist

-END OF REPORT-

APPENDIX I

**LEAD IN DRINKING WATER SAMPLING
CHAINS-OF-CUSTODY & LAB REPORTS**



Results Report

Order ID: 7062671

Westchester Environmental
307 North Walnut Street
West Chester, PA 19380

Project: Rockaway Borough, NJ SD - Lincoln ES
37 Keller Avenue
Rockaway, NJ 07866

Attn: Westchester Environmental

Regulatory ID:

Sample Number: 7062671-01	Site: B-7-S	Sample ID: RLES-LFL-S-B-7-F
Collector: NPA	Collect Date: 06/09/2017 6:52 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	38.8	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 1:00	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7062671-02	Site: B-4-1-S	Sample ID: RLES-LFL-S-B-4-1-F
Collector: NPA	Collect Date: 06/09/2017 6:56 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.95	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 1:10	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7062671-03	Site: CR110-1-S	Sample ID: RLES-MFL-S-CR110-1-F
Collector: NPA	Collect Date: 06/09/2017 7:00 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	19.8	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 1:12	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7062671-04	Site: CR110-DW	Sample ID: RLES-MFL-DW-CR110-F
Collector: NPA	Collect Date: 06/09/2017 7:00 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	87.2	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 1:14	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7062671-05	Site: Principal's Office-S	Sample ID: RLES-MFL-S-Principal's Office-F
Collector: NPA	Collect Date: 06/09/2017 7:02 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	8.90	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 1:16	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 06/19/2017 6:11 pm 7062671
STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 7062671-06	Site: Boy's Rm-1-S	Sample ID: RLES-MFL-S-Boy's Rm-1-F
Collector: NPA	Collect Date: 06/09/2017 7:05 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.53	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 16:49	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062671-07	Site: Girl's Rm-4-S	Sample ID: RLES-2FL-S-Girl's Rm-4-F
Collector: NPA	Collect Date: 06/09/2017 7:08 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.72	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 16:55	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062671-08	Site: Girl's Rm-5-S	Sample ID: RLES-2FL-S-Girl's Rm-5-F
Collector: NPA	Collect Date: 06/09/2017 7:09 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	8.46	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 16:57	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062671-09	Site: Boy's Rm-5-S	Sample ID: RLES-2FL-S-Boy's Rm-5-F
Collector: NPA	Collect Date: 06/09/2017 7:11 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	89.9	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 16:59	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062671-10	Site: Laboratory Control Sample	Sample ID:
Collector:	Collect Date: 06/13/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	15.4	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 17:01	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062671-11	Site: Laboratory Control Sample Duplicate	Sample ID:
Collector:	Collect Date: 06/13/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	15.1	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 17:03	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 06/19/2017 6:11 pm 7062671
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.


Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Alana Kopicz
Project Manager

Report Generated On: 06/19/2017 6:11 pm 7062671
STL_Results Revision #1.6 Effective: 07/09/2014





7062671

Alana Kopicz



1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban.testinglabs.com

Client Name: Westchester Environmental LLC.

Address: 307 N. Walnut Street

West Chester, PA 19380

Contact Name: Noel Abraham

Comments:

Project Name: Rockaway Borough SD

Address: Lincoln Elementary

37 Keller Ave, Rockaway, NJ 07866

Payment / P.O. Info:

Other

72hr

48hr

24hr

1 week

pH < 2

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
Flush	B-7-S	06/09/17	06:52 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-S-B-7-F
Flush	B-4-1-S	06/09/17	06:56 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	RLES-LFL-S-B-4-1-F
Flush	CR110-1-S	06/09/17	07:00 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-CR110-1-F
Flush	CR110-DW	06/09/17	07:00 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-DW-CR110-F
Flush	Principal's Office-S	06/09/17	07:02 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-Principal's Office-F
Flush	Boys's Rm-1-S	06/09/17	07:05 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	RLES-MFL-S-Boys's Rm -1-F
Flush	Girls's Rm-4-S	06/09/17	07:08 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Girl's Rm -4-F
Flush	Girls's Rm-5-S	06/09/17	07:09 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Girl's Rm -5-F
Flush	Boys's Rm-5-S	06/09/17	07:11 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	RLES-2FL-S-Boys's Rm -5-F

Relinquished by:

[Signature]

Received By:

[Signature]

Relinquished by:

[Signature]

Received in Lab By:

[Signature]

Date: 6/13/17
 Time: 09:08
 Date: 6/13/17 Temp °C: 28.0
 Time: 12:30 Acceptable Y/N
 Date: 6/13/17 Temp °C: 27.2
 Time: 15:00 Acceptable Y/N
 Date: 6/13/17 Temp °C:
 Time: 15:00 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water Solid = Raw Sludge Dewatered Sludge soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) Potable Sample Sample Type Key: SWDA Sample Type D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	P = Plastic G = Glass O = Other Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH A = Ascorbic H = HNO ₃ S = OH = O = Other NA = None Required	SWDA Reportin Fax Email Other Return a copy of
Number of containers match <input checked="" type="checkbox"/> Y/N			
All containers intact <input checked="" type="checkbox"/> Y/N			
Tests within holding times <input checked="" type="checkbox"/> Y/N			
40 ml. YGA vials free of headspace? <input checked="" type="checkbox"/> Y/N			

pH ✓ - DMK 6/13



Results Report

Order ID: 7062672

Westchester Environmental
307 North Walnut Street
West Chester, PA 19380

Project: Rockaway Borough, NJ SD - Thomas Jefferson MS
95 E. Main Street
Rockaway, NJ 07866

Attn: Westchester Environmental

Regulatory ID:

Sample Number: 7062672-01 Site: Principals Office Sample ID: RJMS-1FL-S-Principals Office 1-F
Collector: NPA Collect Date: 06/09/2017 7:15 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.12 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:09 RPV

Sample Number: 7062672-02 Site: Home Ec Lab Sample ID: RJMS-1FL-S-Home EC Lab 1-F
Collector: NPA Collect Date: 06/09/2017 7:17 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 9.41 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:10 RPV

Sample Number: 7062672-03 Site: Home Ec Lab Sample ID: RJMS-1FL-S-Home EC Lab 3-F
Collector: NPA Collect Date: 06/09/2017 7:22 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 28.6 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:12 RPV

Sample Number: 7062672-04 Site: Prep Rm 2 Sample ID: RJMS-1FL-S-Prep Rm-2-F
Collector: NPA Collect Date: 06/09/2017 7:24 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.31 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:16 RPV

Sample Number: 7062672-05 Site: Science Rm Sample ID: RJMS-1FL-S-Science Rm 2-F
Collector: NPA Collect Date: 06/09/2017 7:19 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.88 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:14 RPV

Report Generated On: 06/21/2017 10:03 am 7062672
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7062672-06 Site: Science Rm Sample ID: RJMS-1FL-S-Science Rm 5-F
 Collector: NPA Collect Date: 06/09/2017 7:20 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.41 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:20 RPV

Sample Number: 7062672-07 Site: Science Rm Sample ID: RJMS-1FL-S-Science Rm 7-F
 Collector: NPA Collect Date: 06/09/2017 7:20 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.66 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:22 RPV

Sample Number: 7062672-08 Site: Girls Locker Rm Sample ID: RJMS-1FL-S-Girls Locker Rm-F
 Collector: NPA Collect Date: 06/09/2017 7:21 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.18 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:24 RPV

Sample Number: 7062672-09 Site: Boys Locker Rm Sample ID: RJMS-1FL-S-Boys Locker Rm-F
 Collector: NPA Collect Date: 06/09/2017 7:24 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.78 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:26 RPV

Sample Number: 7062672-10 Site: Art Rm Sample ID: RJMS-1FL-S-Art Rm 1-F
 Collector: NPA Collect Date: 06/09/2017 7:26 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.82 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:31 RPV

Sample Number: 7062672-11 Site: Hall o/s Music Sample ID: RJMS-1FL-DW-Hall o/s Music Rm-F
 Collector: NPA Collect Date: 06/09/2017 7:30 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 31.9 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:33 RPV

Sample Number: 7062672-12 Site: Kitchen Sample ID: RJMS-1FL-S-Kitchen 1-F
 Collector: NPA Collect Date: 06/09/2017 7:31 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.1 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 17:35 RPV

Report Generated On: 06/21/2017 10:03 am 7062672
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 7062672-13	Site: Kitchen	Sample ID: RJMS-1FL-S-Kitchen 2-F
Collector: NPA	Collect Date: 06/09/2017 7:32 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	11.9	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 17:37	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-14	Site: CR 101	Sample ID: RJMS-2FL-S-CR 101-F
Collector: NPA	Collect Date: 06/09/2017 7:34 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	24.8	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 17:39	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-15	Site: CR 101	Sample ID: RJMS-1FL-DW-CR 101-F
Collector: NPA	Collect Date: 06/09/2017 7:35 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	7.36	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 17:45	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-16	Site: CR 102	Sample ID: RJMS-1FL-S-CR 102-F
Collector: NPA	Collect Date: 06/09/2017 7:36 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	20.3	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 17:56	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-17	Site: Library	Sample ID: RJMS-1FL-S-Library-F
Collector: NPA	Collect Date: 06/09/2017 7:37 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	29.5	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 17:59	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-18	Site: Library	Sample ID: RJMS-1FL-DW-Library-F
Collector: NPA	Collect Date: 06/09/2017 7:38 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	16.8	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:01	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-19	Site: Girls Rm 1	Sample ID: RJMS-1FL-S-Girls Rm 1-F
Collector: NPA	Collect Date: 06/09/2017 7:39 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	13.7	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:04	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 06/21/2017 10:03 am 7062672
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 7062672-20 Site: CR 105 Sample ID: RJMS-1FL-S-CR 105-F
 Collector: NPA Collect Date: 06/09/2017 7:40 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 22.7 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 18:06 RPV

Sample Number: 7062672-21 Site: CR 105 Sample ID: RJMS-1FL-DW-CR 105-F
 Collector: NPA Collect Date: 06/09/2017 7:41 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 85.5 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 18:08 RPV

Sample Number: 7062672-22 Site: CR 117 Sample ID: RJMS-1FL-S-CR 117-F
 Collector: NPA Collect Date: 06/09/2017 7:42 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 9.29 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 18:11 RPV

Sample Number: 7062672-23 Site: CR 106 Sample ID: RJMS-1FL-S-CR 106-F
 Collector: NPA Collect Date: 06/09/2017 7:43 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 92.6 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 18:14 RPV

Sample Number: 7062672-24 Site: CR 106 Sample ID: RJMS-1FL-DW-CR 106-F
 Collector: NPA Collect Date: 06/09/2017 7:44 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 50.3 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 18:16 RPV

Sample Number: 7062672-25 Site: CR 116 Sample ID: RJMS-1FL-S-CR 116-F
 Collector: NPA Collect Date: 06/09/2017 7:45 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 22.4 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 18:23 RPV

Sample Number: 7062672-26 Site: CR 107 Sample ID: RJMS-1FL-S-CR 107-F
 Collector: NPA Collect Date: 06/09/2017 7:47 am Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 49.8 µg/L EPA 200.8 1.00 1 06/14/17 RJS 06/16/17 18:25 RPV

Report Generated On: 06/21/2017 10:03 am 7062672
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 7062672-27	Site: CR 107	Sample ID: RJMS-1FL-DW-CR 107-F
Collector: NPA	Collect Date: 06/09/2017 7:48 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	113	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:27	RPV
------	-----	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-28	Site: CR 108	Sample ID: RJMS-1FL-S-CR 108-F
Collector: NPA	Collect Date: 06/09/2017 7:49 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	152	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:29	RPV
------	-----	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-29	Site: CR 108	Sample ID: RJMS-1FL-DW-CR 108-F
Collector: NPA	Collect Date: 06/09/2017 7:50 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	49.2	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:31	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-30	Site: CR 115	Sample ID: RJMS-1FL-S-CR 115-F
Collector: NPA	Collect Date: 06/09/2017 7:51 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	128	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:33	RPV
------	-----	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-31	Site: CR 114	Sample ID: RJMS-1FL-S-CR 114-F
Collector: NPA	Collect Date: 06/09/2017 7:52 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	11.5	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:35	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-32	Site: CR 109	Sample ID: RJMS-1FL-S-CR 109-F
Collector: NPA	Collect Date: 06/09/2017 7:53 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	63.4	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:37	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-33	Site: CR 113	Sample ID: RJMS-1FL-S-CR 113-F
Collector: NPA	Collect Date: 06/09/2017 7:54 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	53.6	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:39	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 06/21/2017 10:03 am 7062672
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 7062672-34	Site: CR 110	Sample ID: RJMS-1FL-S-CR 110-F
Collector: NPA	Collect Date: 06/09/2017 7:55 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	20.6	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:41	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-35	Site: CR 110	Sample ID: RJMS-1FL-DW-CR 110-F
Collector: NPA	Collect Date: 06/09/2017 7:56 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	78.6	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:50	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-36	Site: CR 112	Sample ID: RJMS-1FL-DW-CR 112-F
Collector: NPA	Collect Date: 06/09/2017 7:57 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	225	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:56	RPV
------	-----	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-37	Site: CR 112	Sample ID: RJMS-1FL-S-CR 112-F
Collector: NPA	Collect Date: 06/09/2017 7:58 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	95.3	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 18:58	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-38	Site: CR 111	Sample ID: RJMS-1FL-S-CR 111-F
Collector: NPA	Collect Date: 06/09/2017 7:59 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	40.5	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 19:00	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-39	Site: Laboratory Control Sample	Sample ID:
Collector:	Collect Date: 06/13/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	15.2	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 21:08	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062672-40	Site: Laboratory Control Sample Duplicate	Sample ID:
Collector:	Collect Date: 06/13/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	15.2	µg/L	EPA 200.8	1.00	1	06/14/17	RJS	06/16/17 19:04	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 06/21/2017 10:03 am 7062672
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Alana Kopicz
Project Manager

Report Generated On: 06/21/2017 10:03 am 7062672
STL_Results Revision #1.6 Effective: 07/09/2014





7062672

Alana Kopicz



1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

24hr 48hr 72hr

Other

1 week

Client Name: Westchester Environmental LLC.
 Address: 307 N. Walnut Street
 West Chester, PA 19380
 Contact Name: Noel Abraham
 Project Name: Rockaway Borough SD
 Address: Thomas Jefferson Middle
 95 East Main St., Rockaway, NJ 07866
 Phone: 610-883-3839
 Email: nabraham@westchesterenviromental.com
 Payment / P.O. Info:

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type*	Preservative	Location Code
Flush	Principa's Office	06/09/17	07:15 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Principals Office 1-F
Flush	Home Ec Lab	06/09/17	07:17 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Home EC Lab 1-F
Flush	Home Ec Lab	06/09/17	07:22 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Home EC Lab 3-F
Flush	Prep Rm 2	06/09/17	07:24 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Prep Rm-2-F
Flush	Science Rm	06/09/17	07:19 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Science Rm 2-F
Flush	Science Rm	06/09/17	07:20 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Science Rm 5-F
Flush	Science Rm	06/09/17	07:20 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Science Rm 7-F
Flush	Girls Locker Rm	06/09/17	07:21 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S- Girls Locker Rm-F
Flush	Boys Locker Rm	06/09/17	07:24 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Boys Locker Rm-F
Flush	Art Rm	06/09/17	07:26 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Art Rm 1-F

Relinquished by:

Noel Abraham

Received By:

Alana Kopicz

Relinquished by:

Noel Abraham


Received in Lab By:

Noel Abraham

Date: 6/13/17
 Time: 07:00
 Date: 6/13/17 Temp °C: 28.0
 Time: 12:30 Acceptable Y/N
 Date: 6/13/17 Temp °C: 27.2
 Time: 1:00 Acceptable Y/N
 Date: 6/13/17 Temp °C: Acceptable Y/N
 Time: 1:50


Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC	NPW = Non-Potable Water	P = Plastic	SWDA
Number of containers match	Solid = Raw Sludge, Dewatered Sludge soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance)	G = Glass O = Other	Reportin
All containers intact	Potable Sample Sample Type Key: SWDA Sample Type G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	Preservative Key H = Sodium Thiosulphate Acid C = HCl NaOH	Fax
Tests within holding times	D = Distribution IE = Entry Point R = Raw C = Check S = Special M = Maximum Residence	H = Sodium A = Ascorbic H = HNO3 S = OH = O = Other	Email
40 ml VOA vials free of headspace?		NA = None Required	Return a copy of

PH ✓ - BMK 6/13



7062672

Alana Kopicz



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban.testinglabs.com

Standard 24hr 48hr 72hr Other

1 week

Client Name:	Westchester Environmental LLC.	Project Name:	Rockaway Borough SD
Address:	307 N. Walnut Street West Chester, PA 19380	Address:	Thomas Jefferson Middle 95 East Main St., Rockaway, NJ 07866
Contact Name:	Noel Abraham	Payment / P.O. Info:	
Phone:	610-883-3839		
Email:	nabraham@westchesterenviromental.com		

Comments:

Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
Flush / First Draw											
Flush Hall o/s Music	06/09/17	07:30 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-Hall o/s Music Rm-F
Flush Kitchen	06/09/17	07:31 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Kitchen 1-F
Flush Kitchen	06/09/17	07:32 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Kitchen 2-F
Flush CR 101	06/09/17	07:34 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	RJMS-2FL-S-CR 101-F
Flush CR 101	06/09/17	07:35 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 101-F
Flush CR 102	06/09/17	07:36 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	RJMS-1 FL-S-CR 102-F
Flush Library	06/09/17	07:37 AM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Library-F
Flush Library	06/09/17	07:38 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-Library-F
Flush Girls Rm 1	06/09/17	07:39 AM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-Girls Rm 1-F
Flush CR 105	06/09/17	07:40 AM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 105-F

PH-2

Relinquished by: *[Signature]*
 Date: 6/13/17
 Time: 07:00
 Received By: *[Signature]*
 Date: 6/13/17 Temp °C: 28.0
 Time: 12:30 Acceptable Y/N
 Relinquished by: *[Signature]*
 Date: 6/13/17 Temp °C: 27.2
 Time: 1:00 Acceptable Y/N
 Received in Lab By: *[Signature]*
 Date: 6/13/17 Temp °C:
 Time: 15:00 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered Sludge soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	P = Plastic G = Glass O = Other Preservative Key H = Sodium Thiosulphate Acid C = HCl H ₂ SO ₄ NaOH	SWDA Reportin Fax Email Other Return a copy of
Number of containers match <input checked="" type="checkbox"/> Y/N	D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	A = Ascorbic H = HNO ₃ OH = O = Other	
All containers intact <input checked="" type="checkbox"/> Y/N	G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	NA = None Required	
Tests within holding times <input checked="" type="checkbox"/> Y/N			
40 ml VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N			

PH ✓ - 6/13/17



7062672
Alana Kopicz

103/F IMACANTUR ROAD, ROCKAWAY, NJ 07866
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com



Client Name: Westchester Environmental LLC.

Address: 307 N. Walnut Street

West Chester, PA 19380

Contact Name: Noel Abraham

Project Name: Rockaway Borough SD

Address: Thomas Jefferson Middle

95 East Main St., Rockaway, NJ 07866

Payment / P.O. Info:

Phone: 610-883-3839

Email: nabraham@westchesterenv
ironmental.com

Comments:

Flush / First Draw	Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type *	Preservative	Location Code
	CR 105	06/09/17	07:41 AM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 105-F
	CR 117	06/09/17	07:42 AM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 117-F
	CR 106	06/09/17	07:43 AM	NPA	023	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR-106-F
	CR 106	06/09/17	07:44 AM	NPA	024	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR-106-F
	CR 116	06/09/17	07:45 AM	NPA	025	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 116-F
	CR 107	06/09/17	07:47 AM	NPA	026	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 107-F
	CR 107	06/09/17	07:48 AM	NPA	027	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 107-F
	CR 108	06/09/17	07:49 AM	NPA	028	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 108-F
	CR 108	06/09/17	07:50 AM	NPA	029	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 108-F
	CR 115	06/09/17	07:51 AM	NPA	030	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 115-F

PHK2

Relinquished by:

Date: 06/13/17

Time:

Date: 07:00
06/13/17 Temp: 23.0

Time: 1230 Acceptable Y/N

Date: 07:20
06/13/17 Temp: 27.2

Time: 1600 Acceptable Y/N


Received in Lab By:

Date: 06/13/17 Temp: C

Time: 15:00 Acceptable Y/N

PHK - DMK 6/13

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water Solid = Raw Sludge - Dewatered Sludge, soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample Sample Type Key: SWDA Sample Type G = Grab 8 HC = 8 Hour Composite 24 HC = 24 hour Composite	P = Plastic G = Glass O = Other Preservative Key H = Sodium Thiosulphate A = Ascorbic Acid H = HNO3 S = C = HCl H2SO4 NaOH NA = None Required	SWDA Report Fax Email Other Return a copy of
Number of containers match <input checked="" type="checkbox"/> Y/N	D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		
All containers intact <input checked="" type="checkbox"/> Y/N			
Tests within holding times <input checked="" type="checkbox"/> Y/N			
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N			



7062672
Alana Kopicz



1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-0980 - suburbantestinglabs.com

Standard 24hr 48hr 72hr
Other

1 week

Client Name: Westchester Environmental LLC.
 Address: 307 N. Walnut Street
 West Chester, PA 19380
 Contact Name: Noel Abraham
 Phone: 610-883-3839
 Email: nabraham@westchesterenviromental.com
 Project Name: Rockaway Borough SD
 Address: Thomas Jefferson Middle
 95 East Main St., Rockaway, NJ 07866
 Payment / P.O. Info:

Sample Description / Site ID.	Date Sampled	Time Sampled	Samplers	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Location Code
Flush CR 114	06/09/17	07:52 AM	NPA	031	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 114-F
Flush CR 109	06/09/17	07:53 AM	NPA	032	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 109-F
Flush CR 113	06/09/17	07:54 AM	NPA	033	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 113-F
Flush CR 110	06/09/17	07:55 AM	NPA	034	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 110-F
Flush CR 112	06/09/17	07:56 AM	NPA	035	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 110-F
Flush CR 112	06/09/17	07:57 AM	NPA	036	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-DW-CR 112-F
Flush CR 112	06/09/17	07:58 AM	NPA	037	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 112-F
Flush CR 111	06/09/17	07:59 AM	NPA	038	Pb EPA 200.8	1	PW	G	P	H	RJMS-1FL-S-CR 111-F

PH < 2

Relinquished by: *Noel Abraham*
 Received By: *Meredith*
 Relinquished by: *Meredith*
 Received in Lab By: *Ron Miller*

Date: 6/13/17
 Time: 07:50
 Date: 6/13/17
 Temp: 28.0
 Time: 12:30
 Acceptable Y/N
 Date: 6/13/17
 Temp: 27.2
 Time: 1:00
 Acceptable Y/N
 Date: 6/13/17
 Temp: 20.0
 Time: 15:00
 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC	NPW = Non-Potable Water	P = Plastic	SWDA Report
Number of containers match	Solid = Raw Sludge, Dewatered Sludge soil, etc. (reported as mg/l) PW = Potable Water (not for SWDA compliance) SWDA = Safe Drinking Water Act Potable Sample	G = Glass O = Other	Fax
All containers intact	Sample Type Key: SWDA Sample Type G = Grab 8 HC = 8 Hour Composite 24 HC = 24 Hour Composite	Preservative Key H = Sodium Thiophosphate A = Ascorbic Acid C = HCl H ₂ SO ₄ NaOH	Email
Tests within holding times	D = Distribution R = Raw C = Check M = Special Residence	Other OH = S = O = Other	Return a copy of
40 ml. YCA vials free of headspace?		NA = None Required	